

CERTIFICATE OF CONSTANCY OF PERFORMANCE

No.: 0751-CPR-223.5-01

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

Mineral wool products

Thermal insulation products for buildings

Factory made mineral wool (MW) products acc. EN 13162:2012+A1:2015

(details see annex)
produced by or for

Saint Gobain Hellas ABEE

Kleisouras 5

Metamorfoosi 144 52

GREECE

and produced in the manufacturing plant(s)

Plant T, Greece

This certificate attests that all provisions concerning the assessment and verification of Constancy of Performance described in Annex ZA of the standard

EN 13162:2012+A1:2015

under **System 1** for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

Constancy of Performance of the construction product.

This certificate was first issued on 09.06.2016 and will remain valid (but no longer than 27.10.2024) as long as neither the harmonized standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Gräfelfing, 09.06.2023



Dr. Andreas Schmöller

Certification Body

ANNEX TO CERTIFICATE OF CONSTANCY OF PERFORMANCE

No.: 0751-CPR-223.5-01

Factory: Plant T, Greece

Construction product(s): Factory made mineral wool (MW) products acc. EN 13162:2012+A1:2015

Intended use: Thermal insulation products for buildings

Level(s) or class(es)
Reaction to fire: For uses subject to regulations of reaction to fire A1, A2, B, C.
Products for which a clearly identifiable stage in the production process results in an improvement in the reaction to fire classification.

System of Assessment and Verification of Constancy of Performance: 1

Table 1: Description of the building products

Note: All products without facings have fire classification A1

No.	Name	Product Description	Thickness Range Mm	Reaction to fire class	Classification		
					Facing	Loss of Ignition mass %	Thickness Range mm
1	Isover Orsik	board	30 - 160	A1	AL ¹ , YM ² , YA ³	≤ 5,7	≥ 20
				C-s1, d0	AX ⁴		
2	Isover Uni	board	30 - 160	A1	AL ¹ , YM ² , YA ³	≤ 5,7	≥ 20
				C-s1, d0	AX ⁴		
3	Isover Fassil	board	30 - 160	A1	AL ¹ , YM ² , YA ³	≤ 5,7	≥ 20
				C-s1, d0	AX ⁴		
4	Isover Maxil	board	30 - 160	A1	AL ¹ , YM ² , YA ³	≤ 5,7	≥ 20
				C-s1, d0	AX ⁴		
5	Isover N	board	30 - 160	A1	AL ¹ , YM ² , YA ³	≤ 5,7	≥ 20
				C-s1, d0	AX ⁴		
6	Isover Profi Fassade	board	30 - 300	A1	AL ¹ , YM ² , YA ³	≤ 5,7	≥ 20
				C-s1, d0	AX ⁴		
7	Isover Fassade	board	50 - 300	A1	AL ¹ , YM ² , YA ³	≤ 5,7	≥ 20
				C-s1, d0	AX ⁴		

¹ AL - Aluminium compound foil

Classification report: MPA BAU Hannover no. 153214

² YM - Black glass tissue

Classification report: MPA BAU Hannover no. 153139

Note: All products without facings have fire classification A1

³ YA - White glass tissue

Classification report: MPA BAU Hannover no. 152467

⁴ AX - Reinforced aluminum craft foil

Classification report: MPA BAU Hannover no. 153219

Gräfelfing, 09.06.2023



Dr. Andreas Schmeller

Certification Body